PRINTED: 02/15/2011 DEPARTMENT OF HEALTH AND HUMAN SERVICES FORM APPROVED CENTERS FOR MEDICARE & MEDICAID SERVICES OMB NO. 0938-0391 STATEMENT OF DEFICIENCIES (X1) PROVIDER/SUPPLIER/CLIA (X2) MULTIPLE CONSTRUCTION (X3) DATE SURVEY AND PLAN OF CORRECTION **IDENTIFICATION NUMBER:** COMPLETED A. BUILDING B. WING 155176 02/09/2011 NAME OF PROVIDER OR SUPPLIER STREET ADDRESS, CITY, STATE, ZIP CODE 3811 PARNELL AVE **GLENBROOK REHABILITATION & SKILLED NURSING CENTER** FORT WAYNE, IN 46805 SUMMARY STATEMENT OF DEFICIENCIES PROVIDER'S PLAN OF CORRECTION (X4) ID 1D (X5) COMPLETION (EACH DEFICIENCY MUST BE PRECEDED BY FULL PREFIX **PREFIX** (EACH CORRECTIVE ACTION SHOULD BE REGULATORY OR LSC IDENTIFYING INFORMATION) TAG TAG CROSS-REFERENCED TO THE APPROPRIATE DATE DEFICIENCY) K 000 INITIAL COMMENTS K 000 The creation and submission of this plan A Life Safety Code Recertification and State of correction does not constitute an Licensure Survey was conducted by the Indiana admission by this provider of any State Department of Health in accordance with 42 conclusion set forth in the statement of CFR 483.70(a). deficiencies, or of any violation of regulation. Survey Date: 02/09/11 This provider respectfully requests that the Facility Number: 000092 2567 plan of correction be considered as Provider Number: 155176 the letter of credible allegation and request AIM Number: 100266090 a desk review in lieu of a post survey review on or after April 27,2011. More Surveyor: Amy Kelley, Life Safety Code time is being requested for completion of Specialist tag K 021. At this Life Safety Code survey, Glenbrook Rehabilitation and Skilled Nursing Center was found not in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire and the 2000 edition of the National Fire Protection RECEIVED Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2. FEB 2 8 2011 This one story facility with a basement was determined to be of Type V (000) construction LONG TERM CARE DIVISION and was fully sprinklered. The facility has a fire INDIANA STATE DEPARTMENT OF HEALTH alarm system with smoke detection in the corridors and areas open to the corridors. The

Quality Review by Robert Booher, REHS, Life

PROMES e Specialist-Medical Surveyor on

31) 11 0.2714/11.

72 at the time of this survey.

The facility was found not in compliance with the aforementioned regulatory requirements as

facility has a capacity of 90 and had a census of

Y DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

twe Duleton

, (X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 02/15/2011 FORM APPROVED OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01			(X3) DATE SURVEY COMPLETED	
155176		155176	B. WING			02/09/2011	
	ROVIDER OR SUPPLIER	ON & SKILLED NURSING CENTE	R	38	EET ADDRESS, CITY, STATE, ZIP CODE 11 PARNELL AVE DRT WAYNE, IN 46805		01,200 1.1
(X4) ID PREFIX TAG	(EACH DEFICIENC)	TEMENT OF DEFICIENCIES MUST BE PRECEDED BY FULL SC IDENTIFYING INFORMATION)	ID PREFI TAG		PROVIDER'S PLAN OF CORREC (EACH CORRECTIVE ACTION SHO CROSS-REFERENCED TO THE APPI DEFICIENCY)	OULD BE	(X5) COMPLETION DATE
K 000 K 021 SS=E	evidenced by the for NFPA 101 LIFE SA Any door in an exit enclosure, horizont hazardous area endevices arranged to doors by zone or thactivation of: a) the required man b) local smoke determines arranged to doors by zone or thactivation of: a) the required man by local smoke determines arranged to doors by zone or thactivation of:	passageway, stairway al exit, smoke barrier or closure is held open only by a automatically close all such roughout the facility upon nual fire alarm system; ectors designed to detect ough the opening or a required estem; and rinkler system, if installed.		000	What corrective action(s) will be accomplished for those resident to have been affected by the depractice. No residents were identified as be affected. How will you identify other resembly the potential to be affect the same deficient practice and corrective action will be taken. The rolls down doors identified a only ones installed in the facility, doors are only up during meal times.	idents ted by what re the These	
	Based on observatifailed to ensure 2 of openings in the kitch would self close up system. This deficit residents in the material Findings include: Based on observation Supervisor on 02/0 revealed the dining and met the requires	s not met as evidenced by: ion and interview, the facility f 2 roll down doors at the then wall, a hazardous area, on activation of the fire alarm ent practice could affect all in dining room. ion with the Maintenance 9/11 at 1:40 p.m., observation room was open to the corridor ements for a space to be to the corridor. The wall			What measures will be put into what systemic changes you will ensure that the deficient practic not recur Outside contractors have been co rewire the existing the roll down the fire alarm system so that they automatically close upon activation fire alarm system. This process in replacing the existing doors and without the system. This will take the weeks to complete. Maintenance Director and/or desistence all staff, by 2-24-2011, a manually pulling doors down immighted the when fire alarm system is activated. How the corrective action(s) will monitored to ensure the deficient	make to ce does ntacted to doors to will on of the icludes wiring ke up to gnee in about nediately ed.	

DEPARTMENT OF HEALTH AND HUMAN SERVICES CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 02/15/2011 FORM APPROVED OMB NO. 0938-0391

OFILE	VO LOIT MEDICANE	& MEDICAID SERVICES				OMP IAC	. 0938-039
STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01			(X3) DATE SURVEY COMPLETED	
'.	155176		B. WING			02/09/2011	
	ROVIDER OR SUPPLIER	ON & SKILLED NURSING CENTE	R	38	EET ADDRESS, CITY, STATE, ZIP CODE B11 PARNELL AVE ORT WAYNE, IN 46805		
(X4) ID PREFIX TAG	(EACH DEFICIENCY				PROVIDER'S PLAN OF CORRE (EACH CORRECTIVE ACTION SH CROSS-REFERENCED TO THE APP DEFICIENCY)	OULD BE	(X5) COMPLETION DATE
K 021	around the dining room is therefore, considered to be the corridor wall. There were two pass through openings in the corridor wall between the dining room and the kitchen. Each opening was protected with a rolling fiberglass door that could only be released manually. This was acknowledged by the Maintenance Supervisor at the time of observation. 3.1-19(b) NFPA 101 LIFE SAFETY CODE STANDARD		K 046	021	CROSS-REFERENCED TO THE APPROPRIATE		
	lighting system at 3 of 30 seconds. An on every required be lighting system for duration. Equipme the duration of the inspections and test for inspection by the This deficient pract. Findings include: Based on an obser	ery powered emergency 0 day intervals for a minimum annual test shall be conducted attery powered emergency not less than a 1 ½ hour nt shall be fully operational for test. Written records of visual ts shall be kept by the owner a authority having jurisdiction. ice could affect all occupants.		COMMANDED TO THE REAL PROPERTY OF THE PROPERTY	corrective action will be taken All battery operated emergency were tested for 90 minutes on 2- What measures will be put into what systemic changes you wil ensure that the deficient practi not recur Maintenance Director and/or des monitor the annual testing of the How the corrective action(s) w monitored to ensure the deficie practice will not recur, i.e., wh	10-11. o place or l make to ice does signee will lights.	

DEPARTMENT OF HEALTH AND HUMAN SERVICES CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 02/15/2011 FORM APPROVED OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:		ULTIF	PLE CONSTRUCTION 3 01	(X3) DATE SURVEY COMPLETED		
	155176		B. WIN	B. WING			02/09/2011	
	PROVIDER OR SUPPLIER	ON & SKILLED NURSING CENTE	R	38	EET ADDRESS, CITY, STATE, ZIP CODE 311 PARNELL AVE ORT WAYNE, IN 46805			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PROVIDER'S PLAN OF COR PREFIX (EACH CORRECTIVE ACTION TAG CROSS-REFERENCED TO THE A DEFICIENCY)		SHOULD BE COMPLÉTION		
K 046	Continued From page 3 p.m., 21 battery operated emergency lights were observed throughout the facility. Based on an interview with the Maintenance Supervisor at the time of observation, the only emergency lights that received an annual test were the two located in the service hall. 3.1-19(b)		K 046		assurance program will be put place Maintenance Director and/or des monitor the testing of all battery emergency lights monthly. Infor will be submitted and reviewed committee quarterly.			
					Date of compliance: February	10, 2011		
				-				
						٠.		